## CITY OF GRANDE PRAIRIE INSPECTION SERVICES

City Service Centre 9505 – 112 Street, Grande Prairie, Ab. T8V 6H8 780-538-0421

## Prescriptive Summary for Part 9 Buildings: New Construction in Zone 7A

1) Check applicable for proposed construction. Minimum prescriptive Effective Thermal Resistance (ETR) for roofs/walls/floors.

Is a *HRV Proposed?	Yes Complete this Column			<b>No</b> Complete this Column		
Above-Ground Assemblies	Minimum ETR RSI	N/A	Equal or better	Minimum 'ETR' RSI	N/A	Equal or better
Ceiling below attic	8.67			10.43		
Cathedral ceiling OR flat roof	5.02			5.02		
Wall c/w exposed foundation wall > 600mm	2.97			3.08		
Floor over unheated space	5.02			5.02		
Tall Wall	2.97			3.46		
<b>Below-Ground or Ground Contact Assemblies</b>	5					
Wall c/w exposed foundation wall < 600mm	2.98			3.46		
Unheated floor – below frost line	N/A			0		
Unheated floor – above frost line	1.96			1.96		
Heated floor	2.84			2.84		
Slab-on-grade with integral footing	2.84			3.72		
HRV conforms to CAN/CSA-C439, "Rating the Performance of Heat/Energy-Recovery Ventilators" sensible HR efficiency $\geq$ 60%@0°C & $\geq$ 55%@-25°C <b>Yes</b> $\square$						

2) Check applicable proposed construction. Maximum prescriptive overall thermal characteristics for windows and doors.

Fenestration & Door Compone	nts	Maximum U Value	N/A	Equal or less			
Windows		1.60			Min. ER 25		
Exterior doors		1.60			Min. ER 25		
Single exterior door exception		2.60			9.36.2.7.(5), indicate on plans		
Glass block; max area: 1.85m <sup>2</sup>		2.90			9.36.2.7.(4), indicate on plans		
Skylights		2.70			9.36.2.7.(4), indicate on plans		
Attic/access hatches	min RSI=2.6	Yes 🗆			9.36.2.4.(8), indicate on plans		
Garage overhead doors	min RSI=1.1	Yes 🗆			9.36.2.7.(7), indicate on plans		

3) Select **HVAC** components/capacity/standard/ minimum performance; check if applicable.

Equipment	Heating/Cooling Capacity	Standard	Minimum Performance	
Gas-fired forced air furnace	<65.9kW [222,000 Btu/h]	CAN/CSA-P.2	≥ AFUE 92%	Yes 🗆
Gas-fired boiler	≤ 88kW [3000k Btu/h]	CAN/CSA-P.2	≥ AFUE 90%	Yes 🗆
Gas-fired tankless combo space/water	≤ 73.2kW if SWH-based	CAN/CSA-P.9	TPF = 0.65	Yes 🗆
heating	≤ 87.9kW if boiler-based			



## CITY OF GRANDE PRAIRIE INSPECTION SERVICES

City Service Centre 9505 – 112 Street, Grande Prairie, Ab. T8V 6H8 780-538-0421

## 4) Select **Service Water Heating** components/input/standard/performance; check if applicable.

Component	Input	Standard	Performance	
			Requirement	
Gas-fired hot water tank	< 22kW [75,000 Btu/h]	CAN/CSA-P.3	$EF \ge 0.67 - 0.0005V$	Yes 🗆
Gas-fired tankless	>73.2kW [250,000 Btu/h]	CSA 4.3 etc	E <sub>t</sub> ≥ 80%	Yes 🗆
	≤ 73.2kW [250,000 Btu/h]	CAN/CSA-P.7	EF ≥ 0.08	Yes 🗆
Electric tank	≤50-270L [13-71 usg]	CAN/CSA-C191	SL ≤ 35 + 0.20V (top)	Yes 🗆
			SL ≤ 40 + 0.20V (bottom)	Yes 🗆
Electric tankless			Approaching 100%	Yes 🗆

The symbols and abbreviations that appear in this summary have the following meanings:

AFUE = Annual Fuel Utilization Efficiency ETR = Effective Thermal Resistance U Value =  $w/m^2$  K RSI Value =  $m^2k/w$ TPF = Thermal Performance Factor E<sub>t</sub> = Thermal Efficiency